



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

February 11, 2020

Clifford Nooney
Guilderland CSD
PO Box 381
Guilderland Center, NY 12085
TEL: (518) 456-6200

Work Order No: 200130007

RE: 2020 Lead Sampling and Analysis
Farnsworth Middle School

Dear Clifford Nooney:

Adirondack Environmental Services, Inc received 218 samples on 1/30/2020 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

A handwritten signature in black ink, appearing to be "M. Higdon".

Monica Higdon
Laboratory Manager

ELAP#: 10709

CLIENT: Guilderland CSD

Date: 11-Feb-20

Project: 2020 Lead Sampling and Analysis

Lab Order: 200130007

The sampling was performed in accordance with the AES field sampling procedures and/or the client specified sampling procedures. Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers: ND : Not Detected at reporting limit	C: CCV below acceptable Limits
J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
H: Hold time exceeded	Z: Duplication outside acceptable limits
N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-001 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-02 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/3/2020 4:51:22 PM

Lab SampleID: 200130007-002 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-03 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/3/2020 5:02:37 PM

Lab SampleID: 200130007-003 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-04 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/3/2020 5:06:23 PM

Lab SampleID: 200130007-004 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-05 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/3/2020 5:17:36 PM

Lab SampleID: 200130007-005 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-06 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead 6.3 1.0 µg/L 1 2/3/2020 5:21:22 PM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-006 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-07 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 5:25:09 PM

Lab SampleID: 200130007-007 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-08 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **1.9** 1.0 µg/L 1 2/3/2020 5:28:51 PM

Lab SampleID: 200130007-008 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-09 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **2.0** 1.0 µg/L 1 2/3/2020 5:32:34 PM

Lab SampleID: 200130007-009 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-10 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **1.9** 1.0 µg/L 1 2/3/2020 5:36:17 PM

Lab SampleID: 200130007-010 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-11 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **1.9** 1.0 µg/L 1 2/3/2020 5:40:00 PM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-011 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-12 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 5:43:44 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-012 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-13 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 6:02:23 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-013 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-14 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 6:06:08 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-014 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-15 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 6:09:53 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-015 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-16 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 6:13:38 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-016 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-17 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 6:17:24 PM

Lab SampleID: 200130007-017 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-18 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 6:21:06 PM

Lab SampleID: 200130007-018 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-19 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 6:24:49 PM

Lab SampleID: 200130007-019 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-20 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 6:28:32 PM

Lab SampleID: 200130007-020 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-21 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 6:32:15 PM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-021 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-24 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 6:50:54 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-022 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-25 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	2.4	1.0		µg/L	1	2/3/2020 7:02:08 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-023 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-26 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 7:05:53 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-024 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-27 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.4	1.0		µg/L	1	2/3/2020 7:09:38 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-025 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-28 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 7:13:21 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-026 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-29 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.3	1.0		µg/L	1	2/3/2020 7:17:04 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-027 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-30 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.2	1.0		µg/L	1	2/3/2020 7:20:47 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-028 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-31 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	2.2	1.0		µg/L	1	2/3/2020 7:31:58 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-029 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-32 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 7:35:41 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-030 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-33 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 7:39:25 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-031 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-34 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 7:43:09 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-032 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-37 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	2.2	1.0		µg/L	1	2/3/2020 7:54:23 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-033 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-38 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.5	1.0		µg/L	1	2/3/2020 7:58:08 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-034 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-39 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	2.2	1.0		µg/L	1	2/3/2020 8:01:53 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-035 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-40 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 8:05:37 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-036 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-41 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 8:09:20 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-037 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-42 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 8:20:31 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-038 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-45 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 8:24:14 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-039 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-46 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 8:27:58 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-040 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-47 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 8:31:42 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-041 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-48 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 8:42:55 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-042 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-49 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 8:54:10 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-043 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-50 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 9:05:22 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-044 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-51 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 9:09:06 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-045 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-52 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 9:12:50 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-046 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-53 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/3/2020 9:16:33 PM

Lab SampleID: 200130007-047 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-54 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/3/2020 9:20:17 PM

Lab SampleID: 200130007-048 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-55 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/3/2020 9:24:01 PM

Lab SampleID: 200130007-049 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-56 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/3/2020 9:27:45 PM

Lab SampleID: 200130007-050 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-57 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/3/2020 9:31:30 PM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-051 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-58 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 9:35:14 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-052 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-59 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 9:53:58 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-053 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-60 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 9:57:42 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-054 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-61 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	2.0	1.0		µg/L	1	2/3/2020 10:01:26 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200130007-055 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-62 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 10:05:12 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-056 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-63 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 10:08:56 PM

Lab SampleID: 200130007-057 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-66 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 10:12:40 PM

Lab SampleID: 200130007-058 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-67 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 10:16:25 PM

Lab SampleID: 200130007-059 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-68 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 10:20:09 PM

Lab SampleID: 200130007-060 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-70 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 10:23:53 PM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-061 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-71 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 10:42:36 PM

Lab SampleID: 200130007-062 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-73 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 10:53:51 PM

Lab SampleID: 200130007-063 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-74 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 10:57:35 PM

Lab SampleID: 200130007-064 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-75 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 11:01:20 PM

Lab SampleID: 200130007-065 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-76 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/3/2020 11:05:04 PM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-066 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-77 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.1	1.0		µg/L	1	2/3/2020 11:08:49 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200130007-067 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-78 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 11:20:01 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200130007-068 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-79 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 11:23:45 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200130007-069 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-80 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.3	1.0		µg/L	1	2/3/2020 11:27:30 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200130007-070 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-81 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.2	1.0		µg/L	1	2/3/2020 11:31:15 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-071 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-82 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.2	1.0		µg/L	1	2/3/2020 11:35:00 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200130007-072 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-83 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/3/2020 11:46:16 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200130007-073 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-84 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	3.9	1.0		µg/L	1	2/3/2020 11:50:00 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200130007-074 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-85 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	2.1	1.0		µg/L	1	2/3/2020 11:53:45 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200130007-075 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-86 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 12:04:58 AM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-076 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-87 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 12:08:42 AM

Lab SampleID: 200130007-077 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-88 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 12:12:27 AM

Lab SampleID: 200130007-078 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-89 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 12:16:12 AM

Lab SampleID: 200130007-079 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-90 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 12:19:57 AM

Lab SampleID: 200130007-080 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-91 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 12:23:42 AM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-081 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-92 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 12:34:58 AM

Lab SampleID: 200130007-082 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-93 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 12:53:41 AM

Lab SampleID: 200130007-083 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-94 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 12:57:26 AM

Lab SampleID: 200130007-084 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-95 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead 1.2 1.0 µg/L 1 2/4/2020 1:01:12 AM

Lab SampleID: 200130007-085 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-96 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead 1.1 1.0 µg/L 1 2/4/2020 1:04:57 AM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-086 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-97 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 1:08:42 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-087 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-98 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 1:12:27 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-088 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-99 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 1:16:12 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-089 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-100 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 1:19:57 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-090 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-101 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	2.4	1.0		µg/L	1	2/4/2020 1:23:43 AM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-091 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-102 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 1:34:56 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-092 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-103 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 1:46:13 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-093 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-104 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 1:49:58 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-094 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-105 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 1:53:44 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-095 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-106 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 1:57:30 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-096 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-107 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 2:01:15 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-097 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-108 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	4.2	1.0		µg/L	1	2/4/2020 2:05:01 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-098 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-109 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 2:08:46 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-099 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-110 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 2:20:00 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-100 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-111 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 2:23:46 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-101 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-112 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead 1.2 1.0 µg/L 1 2/4/2020 5:51:20 PM

Lab SampleID: 200130007-102 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-115 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 6:02:29 PM

Lab SampleID: 200130007-103 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-116 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead 1.6 1.0 µg/L 1 2/4/2020 6:06:13 PM

Lab SampleID: 200130007-104 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-117 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 6:09:57 PM

Lab SampleID: 200130007-105 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-118 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 6:21:09 PM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-106 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-119 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 6:24:54 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-107 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-120 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.5	1.0		µg/L	1	2/4/2020 6:28:39 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-108 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-121 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.3	1.0		µg/L	1	2/4/2020 6:32:24 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-109 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-122 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 6:36:09 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-110 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-123 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 6:39:52 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-111 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-124 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.1	1.0		µg/L	1	2/4/2020 6:43:35 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-112 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-125 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 6:54:45 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-113 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-126 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.0	1.0		µg/L	1	2/4/2020 7:05:56 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-114 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-127 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	9.2	1.0		µg/L	1	2/4/2020 7:09:40 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-115 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-128 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	3.1	1.0		µg/L	1	2/4/2020 7:13:24 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-116 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-129 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	2.1	1.0		µg/L	1	2/4/2020 7:17:09 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-117 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-130 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 7:20:54 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-118 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-131 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 7:24:39 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-119 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-132 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 7:28:24 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-120 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-133 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	5.7	1.0		µg/L	1	2/4/2020 7:32:07 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-121 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-134 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	4.1	1.0		µg/L	1	2/4/2020 7:50:44 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-122 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-135 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 8:01:55 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-123 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-136 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 8:05:39 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-124 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-137 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 8:09:24 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-125 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-139 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	2.4	1.0		µg/L	1	2/4/2020 8:13:09 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-126 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-140 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 8:16:54 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-127 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-141 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 8:20:40 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-128 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-143 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	4.1	1.0		µg/L	1	2/4/2020 8:24:23 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-129 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-144 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.1	1.0		µg/L	1	2/4/2020 8:28:07 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-130 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-145 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.7	1.0		µg/L	1	2/4/2020 8:39:17 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-131 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-146 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/4/2020 8:43:01 PM

Lab SampleID: 200130007-132 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-147 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/4/2020 8:54:12 PM

Lab SampleID: 200130007-133 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-148 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/4/2020 8:57:57 PM

Lab SampleID: 200130007-134 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-149 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/4/2020 9:01:41 PM

Lab SampleID: 200130007-135 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-150 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/4/2020 9:05:26 PM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-136 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-151 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 9:09:11 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-137 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-152 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 9:12:57 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-138 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-153 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 9:24:09 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-139 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-154 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 9:27:52 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-140 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-155 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 9:31:36 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-141 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-156 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.4	1.0		µg/L	1	2/4/2020 9:42:48 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-142 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-157 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 9:54:01 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-143 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-158 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 9:57:46 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-144 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-159 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 10:08:59 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200130007-145 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-160 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	2.0	1.0		µg/L	1	2/4/2020 10:12:45 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-146 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-161 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 10:16:29 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200130007-147 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-162 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 10:20:13 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200130007-148 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-163 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 10:23:58 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200130007-149 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-164 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.6	1.0		µg/L	1	2/4/2020 10:27:42 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200130007-150 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-165 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 10:31:26 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-151 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-166 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/4/2020 10:35:10 PM

Lab SampleID: 200130007-152 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-167 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/4/2020 10:53:51 PM

Lab SampleID: 200130007-153 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-168 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **5.6** 1.0 µg/L 1 2/4/2020 10:57:36 PM

Lab SampleID: 200130007-154 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-169 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/4/2020 11:01:22 PM

Lab SampleID: 200130007-155 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-242 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **8.0** 1.0 µg/L 1 2/4/2020 11:05:07 PM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-156 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-243 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	2.4	1.0		µg/L	1	2/4/2020 11:08:52 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200130007-157 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-244 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	2.4	1.0		µg/L	1	2/4/2020 11:12:36 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200130007-158 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-245 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 11:16:21 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200130007-159 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-246 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 11:20:05 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200130007-160 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-247 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/4/2020 11:23:50 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-161 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-248 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 11:42:31 PM

Lab SampleID: 200130007-162 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-249 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 11:53:46 PM

Lab SampleID: 200130007-163 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-251 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/4/2020 11:57:32 PM

Lab SampleID: 200130007-164 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-252 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead 2.7 1.0 µg/L 1 2/5/2020 12:01:16 AM

Lab SampleID: 200130007-165 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-253 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/5/2020 12:05:01 AM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-166 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-254 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/5/2020 12:08:46 AM

Lab SampleID: 200130007-167 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-256 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead 517 10.0 µg/L 10 2/5/2020 4:05:58 PM

Lab SampleID: 200130007-168 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-257 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/5/2020 12:23:43 AM

Lab SampleID: 200130007-169 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-258 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/5/2020 12:27:28 AM

Lab SampleID: 200130007-170 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-259 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/5/2020 12:31:13 AM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-171 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-260 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/5/2020 12:34:58 AM

Lab SampleID: 200130007-172 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-274 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/5/2020 12:46:13 AM

Lab SampleID: 200130007-173 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-275 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/5/2020 12:49:59 AM

Lab SampleID: 200130007-174 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-276 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/5/2020 12:53:44 AM

Lab SampleID: 200130007-175 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-277 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/5/2020 12:57:29 AM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-176 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-278 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 1:08:42 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-177 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-279 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 1:12:27 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-178 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-280 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 1:16:12 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-179 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-281 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 1:19:57 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-180 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-282 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 1:23:42 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-181 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-283 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 1:35:00 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-182 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-284 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 1:53:45 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-183 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-285 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 1:57:30 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-184 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-286 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 2:01:16 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-185 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-287 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 2:05:01 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-186 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-288 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 2:08:47 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-187 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-290 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.1	1.0		µg/L	1	2/5/2020 2:12:33 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-188 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-291 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 2:16:18 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-189 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-292 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 2:20:04 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-190 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-293 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 2:23:49 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-191 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-294 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 2:27:35 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-192 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-295 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 2:46:20 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-193 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-296 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 2:50:05 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-194 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-297 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 2:53:51 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-195 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-298 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 2:57:37 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-196 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-299 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 3:01:23 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-197 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-300 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	1.1	1.0		µg/L	1	2/5/2020 3:05:09 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200130007-198 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-301 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 3:08:55 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-199 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-302 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 3:12:41 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-200 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-303 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 3:23:55 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-201 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-304 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/5/2020 3:35:12 AM

Lab SampleID: 200130007-202 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-305 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead 1.9 1.0 µg/L 1 2/5/2020 3:46:30 AM

Lab SampleID: 200130007-203 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-306 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead 5.7 1.0 µg/L 1 2/5/2020 3:50:17 AM

Lab SampleID: 200130007-204 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-307 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/5/2020 3:54:03 AM

Lab SampleID: 200130007-205 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-308 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead ND 1.0 µg/L 1 2/5/2020 3:57:49 AM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-206 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-309 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/5/2020 4:09:03 AM

Lab SampleID: 200130007-207 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-310 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/5/2020 4:12:49 AM

Lab SampleID: 200130007-208 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-311 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/5/2020 4:16:35 AM

Lab SampleID: 200130007-209 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-312 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/5/2020 4:20:21 AM

Lab SampleID: 200130007-210 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-313 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)
 Lead **ND** 1.0 µg/L 1 2/5/2020 4:24:07 AM

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
 Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-211 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-314 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 4:27:54 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-212 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-315 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 4:39:13 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-213 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-316 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 4:42:59 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-214 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-317 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 4:54:14 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200130007-215 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-319 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 1/30/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 4:58:00 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 11-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Farnsworth Middle School

LabWork Order: 200130007
PO#:

Lab SampleID: 200130007-216 **Collection Date:** 1/29/2020
Client Sample ID: GCSD-FMS-320 **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(**Prep:** - 1/30/2020)
Lead **ND** 1.0 µg/L 1 2/5/2020 5:01:46 AM

Lab SampleID: 200130007-217 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-FMS-321 **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(**Prep:** - 1/30/2020)
Lead **ND** 1.0 µg/L 1 2/5/2020 5:05:33 AM

Lab SampleID: 200130007-218 **Collection Date:** 1/28/2020
Client Sample ID: GCSD-FMS-01 **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(**Prep:** - 1/30/2020)
Lead **1.1** 1.0 µg/L 1 2/5/2020 5:09:19 AM



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007

COC Reference: 1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School		Address:								
Send Report to:		Project Name (Location): Farnsworth Middle School			Samplers Name: <i>Ryan Barsky / Mike Wilsey</i>					
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>					
Client Email:										
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis	
				Matrix	C	G				
001	GCSD-FMS-01	1/28/2020	0506	PW		X	1	0	Lead	
002	GCSD-FMS-02	1/28/2020	0507	PW		X	1	0	Lead	
003	GCSD-FMS-03	1/28/2020	0509	PW		X	1	0	Lead	
004	GCSD-FMS-04	1/28/2020	0509	PW		X	1	0	Lead	
005	GCSD-FMS-05	1/28/2020	0509	PW		X	1	0	Lead	
006	GCSD-FMS-06	1/28/2020	0510	PW		X	1	0	Lead	
007	GCSD-FMS-07	1/28/2020	0511	PW		X	1	0	Lead	
008	GCSD-FMS-08	1/28/2020	0511	PW		X	1	0	Lead	
009	GCSD-FMS-09	1/28/2020	0512	PW		X	1	0	Lead	
010	GCSD-FMS-10	1/28/2020	0512	PW		X	1	0	Lead	
011	GCSD-FMS-11	1/28/2020	0513	PW		X	1	0	Lead	
012	GCSD-FMS-12	1/28/2020	0513	PW		X	1	0	Lead	
013	GCSD-FMS-13	1/28/2020	0514	PW		X	1	0	Lead	
014	GCSD-FMS-14	1/28/2020	0514	PW		X	1	0	Lead	
015	GCSD-FMS-15	1/28/2020	0515	PW		X	1	0	Lead	
016	GCSD-FMS-16	1/28/2020	0515	PW		X	1	0	Lead	
Shipment Arrived Via: FedEx UPS Client <u>(AES)</u> Other:				Special Instructions/Remarks:						
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard				PLEASE FILL ALL PINK SHADED AREAS						
NOTE: Samples received after 3:30pm are considered next business day.										
Relinquished by: (Signature)				Received by: (Signature)			Date	Time		
Relinquished by: (Signature)				Received by: (Signature)			Date	Time		
Relinquished by: (Signature)				Received for Laboratory by:			Date	Time		
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: <u>(Y)</u> / N			Received Within Holding Times: <u>(Y)</u> / N			
Bottles AES: <u>(Y)</u> / N				0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃			5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/Na 9=NaOH pl 10=Other_			
							Notes:			
							 200130007			



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007

COC Reference: 1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School		Address:								
Send Report to:		Project Name (Location): Farnsworth Middle School			Samplers Name: <i>Ryan Baisley / mike wilsey</i>					
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>					
Client Email:										
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis	
				Matrix	C	G				
016 017	GCSD-FMS-17	1/28/2020	0515	PW		X	1	0	Lead	
017 018	GCSD-FMS-18	1/28/2020	0514	PW		X	1	0	Lead	
018 019	GCSD-FMS-19	1/28/2020	0516	PW		X	1	0	Lead	
019 020	GCSD-FMS-20	1/28/2020	0516	PW		X	1	0	Lead	
020 021	GCSD-FMS-21	1/28/2020	0517	PW		X	1	0	Lead	
021	GCSD-FMS-22	1/28/2020	0518	PW		X	1	0	Lead	
022	GCSD-FMS-23	1/28/2020	0518	PW		X	1	0	Lead	
021 024	GCSD-FMS-24	1/28/2020	0520	PW		X	1	0	Lead	
022 025	GCSD-FMS-25	1/28/2020	0520	PW		X	1	0	Lead	
023 026	GCSD-FMS-26	1/28/2020	0520	PW		X	1	0	Lead	
024 027	GCSD-FMS-27	1/28/2020	0522	PW		X	1	0	Lead	
025 028	GCSD-FMS-28	1/28/2020	0522	PW		X	1	0	Lead	
026 029	GCSD-FMS-29	1/28/2020	0522	PW		X	1	0	Lead	
027 030	GCSD-FMS-30	1/28/2020	0522	PW		X	1	0	Lead	
028 031	GCSD-FMS-31	1/28/2020	0524	PW		X	1	0	Lead	
029 032	GCSD-FMS-32	1/28/2020	0526	PW		X	1	0	Lead	
Shipment Arrived Via: FedEx UPS Client <input checked="" type="radio"/> AES Other: _____				Special Instructions/Remarks:						
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard										
NOTE: Samples received after 3:30pm are considered next business day.										
PLEASE FILL ALL PINK SHADED AREAS										
Relinquished by: (Signature)				Received by: (Signature)			Date	Time		
Relinquished by: (Signature)				Received by: (Signature)			Date	Time		
Relinquished by: (Signature)				Received for Laboratory by:			Date	Time		
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: <input checked="" type="radio"/> Y / <input type="radio"/> N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____			Received Within Holding Times: <input checked="" type="radio"/> Y / <input type="radio"/> N Notes:			
Bottles AES: <input checked="" type="radio"/> Y / <input type="radio"/> N										



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007

COC Reference: 1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School		Address:	
Send Report to:		Project Name (Location): Farnsworth Middle School	Samplers Name: <i>Ryan Baisley / Mike Wilsey</i>
Client Phone #:		Client PO #:	Samplers Signature: <i>[Signature]</i>
Client Email:			

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
030 033	GCSD-FMS-33	1/28/2020	0527	PW		X	1	0	Lead
031 034	GCSD-FMS-34	1/28/2020	0535	PW		X	1	0	Lead
035	GCSD-FMS-35	1/28/2020	0535	PW		X	1	0	Lead
032 036	GCSD-FMS-37	1/28/2020	0542	PW		X	1	0	Lead
033 037	GCSD-FMS-38	1/28/2020	0542	PW		X	1	0	Lead
034 038	GCSD-FMS-39	1/29/2020	0544	PW		X	1	0	Lead
035 039	GCSD-FMS-40	1/28/2020	0544	PW		X	1	0	Lead
036 040	GCSD-FMS-41	1/28/2020	0544	PW		X	1	0	Lead
037 041	GCSD-FMS-42	1/28/2020	0545	PW		X	1	0	Lead
038 042	GCSD-FMS-45	1/28/2020	0545	PW		X	1	0	Lead
039 043	GCSD-FMS-46	1/28/2020	0546	PW		X	1	0	Lead
040 044	GCSD-FMS-47	1/28/2020	0546	PW		X	1	0	Lead
041 045	GCSD-FMS-48	1/28/2020	0548	PW		X	1	0	Lead
042 046	GCSD-FMS-49	1/28/2020	0549	PW		X	1	0	Lead
043 047	GCSD-FMS-50	1/28/2020	0549	PW		X	1	0	Lead
044 048	GCSD-FMS-51	1/28/2020	0550	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other: _____	Special Instructions/Remarks:
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard	
NOTE: Samples received after 3:30pm are considered next business day.	PLEASE FILL ALL PINK SHADED AREAS

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time
	<i>Kraz</i>	1/30/20	9:32am

Sample Temperature Ambient Notes: Ice preservation not required Bottles AES: <u>Y</u> / N	Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____	Received Within Holding Times: <u>Y</u> / N Notes:
--	---	--



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007

COC Reference: 1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School		Address:								
Send Report to:		Project Name (Location): Farnsworth Middle School			Samplers Name: <i>Ryan Baisley / Mike Wilsey</i>					
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>					
Client Email:										
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis	
				Matrix	C	G				
045	049 GCSD-FMS-52	1/26/2020	0551	PW		X	1	0	Lead	
046	050 GCSD-FMS-53	1/28/2020	0552	PW		X	1	0	Lead	
047	051 GCSD-FMS-54	1/28/2020	0553	PW		X	1	0	Lead	
048	052 GCSD-FMS-55	1/28/2020	0554	PW		X	1	0	Lead	
049	053 GCSD-FMS-56	1/28/2020	0555	PW		X	1	0	Lead	
050	054 GCSD-FMS-57	1/28/2020	0558	PW		X	1	0	Lead	
051	055 GCSD-FMS-58	1/28/2020	0559	PW		X	1	0	Lead	
052	056 GCSD-FMS-59	1/28/2020	0559	PW		X	1	0	Lead	
053	057 GCSD-FMS-60	1/28/2020	0600	PW		X	1	0	Lead	
054	058 GCSD-FMS-61	1/28/2020	0601	PW		X	1	0	Lead	
055	059 GCSD-FMS-62	1/28/2020	0601	PW		X	1	0	Lead	
056	060 GCSD-FMS-63	1/28/2020	0601	PW		X	1	0	Lead	
057	061 GCSD-FMS-66	1/28/2020	0601	PW		X	1	0	Lead	
058	062 GCSD-FMS-67	1/28/2020	0603	PW		X	1	0	Lead	
059	063 GCSD-FMS-68	1/28/2020	0605	PW		X	1	0	Lead	
060	064 GCSD-FMS-70	1/28/2020	0608	PW		X	1	0	Lead	
Shipment Arrived Via: FedEx UPS Client <input checked="" type="radio"/> AES Other: _____				Special Instructions/Remarks:						
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard				PLEASE FILL ALL PINK SHADED AREAS						
NOTE: Samples received after 3:30pm are considered next business day.										
Relinquished by: (Signature)				Received by: (Signature)				Date	Time	
Relinquished by: (Signature)				Received by: (Signature)				Date	Time	
Relinquished by: (Signature)				Received for Laboratory by:				Date	Time	
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: <input checked="" type="radio"/> Y / <input type="radio"/> N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____				Received Within Holding Times: <input checked="" type="radio"/> Y / <input type="radio"/> N		
Bottles AES: <input checked="" type="radio"/> Y / <input type="radio"/> N								Notes:		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007

COC Reference: 1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School		Address:	
Send Report to:	Project Name (Location): Farnsworth Middle School		Samplers Name: <i>Ryan Baisley / Mike Wilsey</i>
Client Phone #:	Client PO #:	Samplers Signature: <i>[Signature]</i>	
Client Email:			

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
061 065	GCSD-FMS-71	1/28/2020	0609	PW		X	1	0	Lead
062 066	GCSD-FMS-72	1/28/2020	0609	PW		X	1	0	Lead
063 067	GCSD-FMS-73	1/28/2020	0611	PW		X	1	0	Lead
064 068	GCSD-FMS-74	1/28/2020	0611	PW		X	1	0	Lead
065 069	GCSD-FMS-75	1/28/2020	0613	PW		X	1	0	Lead
066 070	GCSD-FMS-76	1/28/2020	0613	PW		X	1	0	Lead
067 071	GCSD-FMS-77	1/28/2020	0614	PW		X	1	0	Lead
068 072	GCSD-FMS-78	1/28/2020	0614	PW		X	1	0	Lead
069 073	GCSD-FMS-79	1/28/2020	0614	PW		X	1	0	Lead
070 074	GCSD-FMS-80	1/28/2020	0615	PW		X	1	0	Lead
071 075	GCSD-FMS-81	1/28/2020	0615	PW		X	1	0	Lead
072 076	GCSD-FMS-82	1/28/2020	0616	PW		X	1	0	Lead
073 077	GCSD-FMS-83	1/28/2020	0617	PW		X	1	0	Lead
074 078	GCSD-FMS-84	1/28/2020	0617	PW		X	1	0	Lead
075 079	GCSD-FMS-85	1/28/2020	0618	PW		X	1	0	Lead
076 080	GCSD-FMS-86	1/28/2020	0618	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:	Special Instructions/Remarks:
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard	

NOTE: Samples received after 3:30pm are considered next business day. **PLEASE FILL ALL PINK SHADED AREAS**

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007

COC Reference: 1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School		Address:							
Send Report to:		Project Name (Location): Farnsworth Middle School			Samplers Name: <i>Ryan Bawley/mike wisley</i>				
Client Phone #:		Client PO #:			Samplers Signature: <i>RN</i>				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
076	081 GCSD-FMS-87	1/26/2020	0619	PW		X	1	0	Lead
077	082 GCSD-FMS-88	1/28/2020	0619	PW		X	1	0	Lead
078	083 GCSD-FMS-89	1/28/2020	0619	PW		X	1	0	Lead
079	084 GCSD-FMS-90	1/28/2020	0622	PW		X	1	0	Lead
080	085 GCSD-FMS-91	1/28/2020	0622	PW		X	1	0	Lead
081	086 GCSD-FMS-92	1/28/2020	0622	PW		X	1	0	Lead
082	087 GCSD-FMS-93	1/28/2020	0623	PW		X	1	0	Lead
083	088 GCSD-FMS-94	1/28/2020	0623	PW		X	1	0	Lead
084	089 GCSD-FMS-95	1/28/2020	0622	PW		X	1	0	Lead
085	090 GCSD-FMS-96	1/28/2020	0622	PW		X	1	0	Lead
086	091 GCSD-FMS-97	1/28/2020	0622	PW		X	1	0	Lead
087	092 GCSD-FMS-98	1/28/2020	0620	PW		X	1	0	Lead
088	093 GCSD-FMS-99	1/28/2020	0624	PW		X	1	0	Lead
089	094 GCSD-FMS-100	1/28/2020	0624	PW		X	1	0	Lead
090	095 GCSD-FMS-101	1/28/2020	0625	PW		X	1	0	Lead
091	096 GCSD-FMS-102	1/28/2020	0625	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:				Special Instructions/Remarks:					
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard				PLEASE FILL ALL PINK SHADED AREAS					
NOTE: Samples received after 3:30pm are considered next business day.									
Relinquished by: (Signature)				Received by: (Signature)			Date	Time	
Relinquished by: (Signature)				Received by: (Signature)			Date	Time	
Relinquished by: (Signature)				Received for Laboratory by:			Date	Time	
				<i>Kraz</i>			1/30/20	932am	
Sample Temperature Ambient Notes: Ice preservation not required		Properly Preserved: <u>Y</u> / N			Received Within Holding Times: <u>Y</u> / N				
		0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃			5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other				
Bottles AES: <u>Y</u> / N									



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007

COC Reference: 1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School			Address:							
Send Report to:			Project Name (Location): Farnsworth Middle School			Samplers Name: <i>Ryan Baistley</i>				
Client Phone #:			Client PO #:			Samplers Signature: <i>[Signature]</i>				
Client Email:										
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis	
				Matrix	C	G				
092	097 GCSD-FMS-103	1/28/2020	619	PW		X	1	0	Lead	
093	098 GCSD-FMS-104	1/28/2020	619	PW		X	1	0	Lead	
094	099 GCSD-FMS-105	1/28/2020	620	PW		X	1	0	Lead	
095	100 GCSD-FMS-106	1/28/2020	620	PW		X	1	0	Lead	
096	101 GCSD-FMS-107	1/28/2020	620	PW		X	1	0	Lead	
097	102 GCSD-FMS-108	1/28/2020	622	PW		X	1	0	Lead	
098	103 GCSD-FMS-109	1/28/2020	622	PW		X	1	0	Lead	
099	104 GCSD-FMS-110	1/28/2020	623	PW		X	1	0	Lead	
100	105 GCSD-FMS-111	1/28/2020	623	PW		X	1	0	Lead	
101	106 GCSD-FMS-112	1/28/2020	624	PW		X	1	0	Lead	
102	107 GCSD-FMS-115	1/28/2020	624	PW		X	1	0	Lead	
103	108 GCSD-FMS-116	1/28/2020	508	PW		X	1	0	Lead	
104	109 GCSD-FMS-117	1/28/2020	508	PW		X	1	0	Lead	
105	110 GCSD-FMS-118	1/28/2020	508	PW		X	1	0	Lead	
106	111 GCSD-FMS-119	1/28/2020	509	PW		X	1	0	Lead	
107	112 GCSD-FMS-120	1/28/2020	509	PW		X	1	0	Lead	
Shipment Arrived Via: FedEx UPS Client <input checked="" type="radio"/> AES Other:				Special Instructions/Remarks:						
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard				PLEASE FILL ALL PINK SHADED AREAS						
NOTE: Samples received after 3:30pm are considered next business day.										
Relinquished by: (Signature)				Received by: (Signature)			Date	Time		
Relinquished by: (Signature)				Received by: (Signature)			Date	Time		
Relinquished by: (Signature)				Received for Laboratory by:			Date	Time		
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: <input checked="" type="radio"/> Y / <input type="radio"/> N			Received Within Holding Times: <input checked="" type="radio"/> Y / <input type="radio"/> N			
Bottles AES: <input checked="" type="radio"/> Y / <input type="radio"/> N				0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃			5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other_____			



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007

COC Reference: 1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School		Address:							
Send Report to:		Project Name (Location): Farnsworth Middle School			Samplers Name: <i>Ryan Bailey</i>				
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
108 113	GCSD-FMS-121	1/28/2020	510	PW		X	1	0	Lead
109 114	GCSD-FMS-122	1/28/2020	510	PW		X	1	0	Lead
110 115	GCSD-FMS-123	1/28/2020	511	PW		X	1	0	Lead
111 116	GCSD-FMS-124	1/28/2020	511	PW		X	1	0	Lead
112 117	GCSD-FMS-125	1/28/2020	511	PW		X	1	0	Lead
113 118	GCSD-FMS-126	1/28/2020	512	PW		X	1	0	Lead
114 119	GCSD-FMS-127	1/28/2020	513	PW		X	1	0	Lead
115 120	GCSD-FMS-128	1/28/2020	513	PW		X	1	0	Lead
116 121	GCSD-FMS-129	1/28/2020	513	PW		X	1	0	Lead
117 122	GCSD-FMS-130	1/28/2020	517	PW		X	1	0	Lead
118 123	GCSD-FMS-131	1/28/2020	517	PW		X	1	0	Lead
119 124	GCSD-FMS-132	1/28/2020	644	PW		X	1	0	Lead
120 125	GCSD-FMS-133	1/28/2020	0519	PW		X	1	0	Lead
121 126	GCSD-FMS-134	1/28/2020	0604	PW		X	1	0	Lead
122 127	GCSD-FMS-135	1/28/2020	0648	PW		X	1	0	Lead
123 128	GCSD-FMS-136	1/28/2020	547	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:				Special Instructions/Remarks:					
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.				PLEASE FILL ALL PINK SHADED AREAS					
Relinquished by: (Signature)				Received by: (Signature)			Date	Time	
Relinquished by: (Signature)				Received by: (Signature)			Date	Time	
Relinquished by: (Signature) <i>[Signature]</i>				Received for Laboratory by: <i>[Signature]</i>			Date 1/30/20	Time 9:30am	
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____			Received Within Holding Times: <u>Y</u> / N Notes:		
Bottles AES: <u>Y</u> / N									



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007
 COC Reference: 1378

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School		Address:	
Send Report to:		Project Name (Location): Farnsworth Middle School	Samplers Name: <i>Ryan Bewley</i>
Client Phone #:		Client PO #:	Samplers Signature: <i>[Signature]</i>
Client Email:			

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
124	129 GCSD-FMS-137	1/28/2020	547	PW		X	1	0	Lead
	130 GCSD-FMS-138			PW		X	1	0	Lead
125	131 GCSD-FMS-139	1/28/2020	645	PW		X	1	0	Lead
126	132 GCSD-FMS-140	1/28/2020	645	PW		X	1	0	Lead
127	133 GCSD-FMS-141	1/28/2020	602	PW		X	1	0	Lead
128	134 GCSD-FMS-142			PW		X	1	0	Lead
129	135 GCSD-FMS-143	1/28/2020	528	PW		X	1	0	Lead
130	136 GCSD-FMS-144	1/30/2020	514	PW		X	1	0	Lead
131	137 GCSD-FMS-145	1/30/2020	0514	PW		X	1	0	Lead
132	138 GCSD-FMS-146	1/28/2020	0559	PW		X	1	0	Lead
133	139 GCSD-FMS-147	1/28/2020	600	PW		X	1	0	Lead
134	140 GCSD-FMS-148	1/28/2020	547600	PW		X	1	0	Lead
135	141 GCSD-FMS-149	1/28/2020	547600	PW		X	1	0	Lead
136	142 GCSD-FMS-150	1/28/2020	605	PW		X	1	0	Lead
137	143 GCSD-FMS-151	1/28/2020	605	PW		X	1	0	Lead
138	144 GCSD-FMS-152	1/28/2020	605	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:	Special Instructions/Remarks: PLEASE FILL ALL PINK SHADED AREAS
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard	

NOTE: Samples received after 3:30pm are considered next business day.			
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time
	<i>[Signature]</i>	1/30/20	932am

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: (Y / N) 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____	Received Within Holding Times: (Y / N) Notes:
Bottles AES: (Y / N)		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007

COC Reference: 1378

A full service analytical research laboratory offering solutions to environmental concerns

Guiderland Central School		Address:	
Send Report to:		Project Name (Location): Farnsworth Middle School	Samplers Name: <i>Ryan Baisley</i>
Client Phone #:		Client PO #:	Samplers Signature: <i>[Signature]</i>
Client Email:			

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis	
				Matrix	C	G				
139	138145	GCSD-FMS-153	1/28/2020	608	PW		X	1	0	Lead
140	139146	GCSD-FMS-154	1/28/2020	608	PW		X	1	0	Lead
141	140147	GCSD-FMS-155	1/28/2020	609	PW		X	1	0	Lead
142	141148	GCSD-FMS-156	1/28/2020	610	PW		X	1	0	Lead
143	142149	GCSD-FMS-157	1/28/2020	610	PW		X	1	0	Lead
144	143150	GCSD-FMS-158	1/28/2020	611	PW		X	1	0	Lead
145	144151	GCSD-FMS-159	1/28/2020	611	PW		X	1	0	Lead
146	145152	GCSD-FMS-160	1/28/2020	613	PW		X	1	0	Lead
147	146153	GCSD-FMS-161	1/28/2020	612	PW		X	1	0	Lead
148	147154	GCSD-FMS-162	1/28/2020	612	PW		X	1	0	Lead
149	148155	GCSD-FMS-163	1/28/2020	612	PW		X	1	0	Lead
150	149156	GCSD-FMS-164	1/28/2020	614	PW		X	1	0	Lead
151	150157	GCSD-FMS-165	1/28/2020	614	PW		X	1	0	Lead
152	151158	GCSD-FMS-166	1/28/2020	618	PW		X	1	0	Lead
153	152159	GCSD-FMS-167	1/28/2020	618	PW		X	1	0	Lead
154	153160	GCSD-FMS-168	1/28/2020	616	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>(AES)</u> Other: _____	Special Instructions/Remarks:
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard	

NOTE: Samples received after 3:30pm are considered next business day. **PLEASE FILL ALL PINK SHADED AREAS**

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time

Sample Temperature Ambient Notes: Ice preservation not required Bottles AES: <u>Y</u> / N	Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____	Received Within Holding Times: <u>Y</u> / N Notes:
--	---	--



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007

COC Reference: 1378

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School		Address:	
Send Report to:		Project Name (Location): Farnsworth Middle School	Samplers Name: <i>Ryan Bausley</i>
Client Phone #:		Client PO #:	Samplers Signature: <i>[Signature]</i>
Client Email:			

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
155	154161 GCSD-FMS-169	1/28/2020	616	PW		X	1	0	Lead
156	155162 GCSD-FMS-242	1/30/2020	0500	PW		X	1	0	Lead
157	156163 GCSD-FMS-243	1/30/2020	0500	PW		X	1	0	Lead
158	157164 GCSD-FMS-244	1/30/2020	0500	PW		X	1	0	Lead
159	158165 GCSD-FMS-245	1/29/2020	643	PW		X	1	0	Lead
160	159166 GCSD-FMS-246	1/29/2020	643	PW		X	1	0	Lead
161	160167 GCSD-FMS-247	1/29/2020	643	PW		X	1	0	Lead
162	161168 GCSD-FMS-248	1/29/2020	644	PW		X	1	0	Lead
163	162169 GCSD-FMS-249	1/29/2020	644	PW		X	1	0	Lead
	-170 GCSD-FMS-250			PW		X	1	0	Lead
164	163171 GCSD-FMS-251	1/30/2020	0620	PW		X	1	0	Lead
165	164172 GCSD-FMS-252	1/30/2020	0602	PW		X	1	0	Lead
166	165173 GCSD-FMS-253	1/30/2020	0515	PW		X	1	0	Lead
167	166174 GCSD-FMS-254	1/30/2020	0515	PW		X	1	0	Lead
	-175 GCSD-FMS-255			PW		X	1	0	Lead
168	167176 GCSD-FMS-256	1/30/2020	0553	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <input checked="" type="radio"/> AES Other:	Special Instructions/Remarks:
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard	

NOTE: Samples received after 3:30pm are considered next business day. **PLEASE FILL ALL PINK SHADED AREAS**

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007

COC Reference: 1378

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School		Address:								
Send Report to:		Project Name (Location): Farnsworth Middle School			Samplers Name: <i>Ryan Baisley</i>					
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>					
Client Email:										
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis	
				Matrix	C	G				
169	168177 GCSD-FMS-257	1/30/2020	0600	PW		X	1	0	Lead	
170	169178 GCSD-FMS-258	1/29/2020	640	PW		X	1	0	Lead	
171	170179 GCSD-FMS-259	1/29/2020	640	PW		X	1	0	Lead	
172	171180 GCSD-FMS-260	1/29/2020	640	PW		X	1	0	Lead	
173	172181 GCSD-FMS-274	1/28/2020	636	PW		X	1	0	Lead	
174	173182 GCSD-FMS-275	1/28/2020	633	PW		X	1	0	Lead	
175	174183 GCSD-FMS-276	1/28/2020	642	PW		X	1	0	Lead	
176	175184 GCSD-FMS-277	1/28/2020	642	PW		X	1	0	Lead	
177	176185 GCSD-FMS-278	1/28/2020	642	PW		X	1	0	Lead	
178	177186 GCSD-FMS-279	1/28/2020	640	PW		X	1	0	Lead	
179	178187 GCSD-FMS-280	1/28/2020	640	PW		X	1	0	Lead	
180	179188 GCSD-FMS-281	1/28/2020	640	PW		X	1	0	Lead	
181	180189 GCSD-FMS-282	1/28/2020	621	PW		X	1	0	Lead	
182	181190 GCSD-FMS-283	1/28/2020	621	PW		X	1	0	Lead	
183	182191 GCSD-FMS-284	1/28/2020	622	PW		X	1	0	Lead	
184	183192 GCSD-FMS-285	1/28/2020	622	PW		X	1	0	Lead	
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:				Special Instructions/Remarks:						
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard				PLEASE FILL ALL PINK SHADED AREAS						
NOTE: Samples received after 3:30pm are considered next business day.				Relinquished by: (Signature)		Received by: (Signature)		Date	Time	
				Relinquished by: (Signature)		Received by: (Signature)		Date	Time	
				Relinquished by: (Signature) <i>[Signature]</i>		Received for Laboratory by: <i>[Signature]</i>		Date 1/30/20	Time 9:32am	
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____				Received Within Holding Times: <u>Y</u> / N		
Bottles AES: <u>Y</u> / N							Notes:			



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007

COC Reference: 1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School		Address:										
Send Report to:		Project Name (Location): Farnsworth Middle School			Samplers Name: <i>Ryan Balsley</i>							
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>							
Client Email:												
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis			
				Matrix	C	G						
185	184193	GCSD-FMS-286	1/28/2020	623	PW		X	1	0	Lead		
186	185194	GCSD-FMS-287	1/28/2020	623	PW		X	1	0	Lead		
187	186195	GCSD-FMS-288	1/28/2020	625	PW		X	1	0	Lead		
	196	GCSD-FMS-289	1/28/2020	630	PW		X	1	0	Lead observation <i>(CLB)</i>		
188	187197	GCSD-FMS-290	1/29/2020	630	PW		X	1	0	Lead		
189	188198	GCSD-FMS-291	1/29/2020	631	PW		X	1	0	Lead		
190	189199	GCSD-FMS-292	1/29/2020	631	PW		X	1	0	Lead		
191	190200	GCSD-FMS-293	1/29/2020	631	PW		X	1	0	Lead		
192	191201	GCSD-FMS-294	1/30/2020	0520	PW		X	1	0	Lead		
193	192202	GCSD-FMS-295	1/30/2020	0520	PW		X	1	0	Lead		
194	193203	GCSD-FMS-296	1/29/2020	639	PW		X	1	0	Lead		
195	194204	GCSD-FMS-297	1/29/2020	639	PW		X	1	0	Lead		
196	195205	GCSD-FMS-298	1/29/2020	639	PW		X	1	0	Lead		
197	196206	GCSD-FMS-299	1/30/2020	0606	PW		X	1	0	Lead		
198	197207	GCSD-FMS-300	1/30/2020	610	PW		X	1	0	Lead		
199	198208	GCSD-FMS-301	1/29/2020	628	PW		X	1	0	Lead		
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:					Special Instructions/Remarks:							
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard					PLEASE FILL ALL PINK SHADED AREAS							
NOTE: Samples received after 3:30pm are considered next business day.												
Relinquished by: (Signature)					Received by: (Signature)			Date	Time			
Relinquished by: (Signature)					Received by: (Signature)			Date	Time			
Relinquished by: (Signature)					Received for Laboratory by:			Date	Time			
Sample Temperature Ambient Notes: Ice preservation not required					Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other_____				Received Within Holding Times: <u>Y</u> / N Notes:			
Bottles AES: Y / N												



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 200130007

COC Reference: 1378

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School		Address:								
Send Report to:		Project Name (Location): Farnsworth Middle School			Samplers Name: <i>Ryan Balsky</i>					
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>					
Client Email:										
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis	
				Matrix	C	G				
200	199209 GCDS-FMS-302	1/30/2020	0620	PW		X	1	0	Lead	
201	200210 GCDS-FMS-303	1/30/2020	0620	PW		X	1	0	Lead	
202	201211 GCDS-FMS-304	1/29/2020	0600	PW		X	1	0	Lead	
203	202212 GCDS-FMS-305	1/29/2020	0600	PW		X	1	0	Lead	
204	203213 GCDS-FMS-306	1/29/2020	0600	PW		X	1	0	Lead	
205	204214 GCDS-FMS-307	1/29/2020	0630	PW		X	1	0	Lead	
206	205215 GCDS-FMS-308	1/28/2020	0602	PW		X	1	0	Lead	
207	206216 GCDS-FMS-309	1/28/2020	0605	PW		X	1	0	Lead	
208	207217 GCDS-FMS-310	1/28/2020	0517	PW		X	1	0	Lead	
209	208218 GCDS-FMS-311	1/28/2020	0525	PW		X	1	0	Lead	
210	209219 GCDS-FMS-312	1/28/2020	0547	PW		X	1	0	Lead	
211	210220 GCDS-FMS-313	1/28/2020	0550	PW		X	1	0	Lead	
212	211221 GCDS-FMS-314	1/28/2020	0605	PW		X	1	0	Lead	
213	212222 GCDS-FMS-315	1/29/2020	0609	PW		X	1	0	Lead	
214	213223 GCDS-FMS-316	1/29/2020	0609	PW		X	1	0	Lead	
215	214224 GCDS-FMS-317	1/29/2020	0619	PW		X	1	0	Lead	
Shipment Arrived Via: FedEx UPS Client <input checked="" type="radio"/> AES Other: _____				Special Instructions/Remarks:						
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard				PLEASE FILL ALL PINK SHADED AREAS						
NOTE: Samples received after 3:30pm are considered next business day.										
Relinquished by: (Signature)				Received by: (Signature)			Date	Time		
Relinquished by: (Signature)				Received by: (Signature)			Date	Time		
Relinquished by: (Signature)				Received for Laboratory by:			Date	Time		
Sample Temperature Ambient				Properly Preserved: <input checked="" type="radio"/> Y / <input type="radio"/> N			Received Within Holding Times: <input checked="" type="radio"/> Y / <input type="radio"/> N			
Notes: Ice preservation not required				0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____			Notes:			
Bottles AES: <input checked="" type="radio"/> Y / <input type="radio"/> N										



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: **200130007**

COC Reference: **1378**

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School		Address:							
Send Report to:		Project Name (Location): Farnsworth Middle School				Samplers Name: <i>Ryan Bardsley</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
216 215	225 GCDS-FMS-319	1/29/2020	0628	PW		X	1	0	Lead
217 216	226 GCDS-FMS-320	1/29/2020	0644	PW		X	1	0	Lead
218 217	227 GCDS-FMS-321	1/30/2020	0610	PW		X	1	0	Lead
*	218 GCSD-FMS-01	1/28/2020	0606	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:			Special Instructions/Remarks: <i>* added back in per Ryan B.</i>		
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard			PLEASE FILL ALL PINK SHADED AREAS		
NOTE: Samples received after 3:30pm are considered next business day.					
Relinquished by: (Signature)	Received by: (Signature)	Date	Time		
Relinquished by: (Signature)	Received by: (Signature)	Date	Time		
Relinquished by: (Signature) <i>[Signature]</i>	Received for Laboratory by: <i>knaz</i>	Date 1/30/20	Time 932am		
Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N		Received Within Holding Times: Y / N		Notes:
Bottles AES: Y / N	0=None 1=H2SO4 pH<2 2=HNO3 pH<2 3=HCl pH<2 4=Na2S2O3	5=NH4Cl 6=Ascorbic Acid 7= 8= 9= 10			





Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.